

PROVISIONAL ANSWER KEY

Paper: Kerala State Electricity Duty Act and Rules ...(Paper II)
Date of Test 29-04-2022

Question1:-Which clause in Kerala Electricity Supply Code, 2014 permits licensee to undertake distribution through a franchisee?

- A:-3
- B:-25
- C:-55
- D:-57

Correct Answer:- Option-D

Question2:-What is the supply voltage for a consumer having contract demand 8000 kVA?

- A:-33 kV
- B:-11 kV
- C:-66 kV
- D:-110 kV

Correct Answer:- Option-A

Question3:-Which clause in Kerala Electricity Supply Code, 2014 regulates parallel operation of generators of the consumer?

- A:-12
- B:-18
- C:-17
- D:-10

Correct Answer:- Option-B

Question4:-Which clause in Kerala Electricity Supply Code, 2014 restricts resale of electricity?

- A:-60
- B:-50
- C:-55
- D:-56

Correct Answer:- Option-C

Question5:-Which section in the Kerala Lifts and Escalators Act, 2013 envisages power of entry to Inspector?

- A:-8
- B:-13
- C:-12
- D:-10

Correct Answer:- Option-D

Question6:-Which section in the Kerala Lifts and Escalators Act, 2013 insists previous permission in writing of the Inspector for any addition/alteration of life/escalator installation?

- A:-4
- B:-3
- C:-8
- D:-9

Correct Answer:- Option-C

Question7:-Which section in the Kerala Lifts and Escalators Act, 2013 empowers the Inspector to cancel or suspend license?

- A:-7
- B:-4
- C:-6
- D:-20

Correct Answer:- Option-A

Question8:-What is the time limit for issuing a license for lift?

- A:-30 days
- B:-15 days
- C:-45 days
- D:-2 months

Correct Answer:- Option-B

Question9:-Which is the form for issuing license to lift/escalator?

- A:-Form G
- B:-Form D
- C:-Form F
- D:-Form E

Correct Answer:- Option-C

Question10:-What is the fee for renewal of life license?

- A:-Rs. 1,500
- B:-Rs. 2,000
- C:-Rs. 500
- D:-Rs. 1,000

Correct Answer:- Option-D

Question11:-Which is the form of work completion report from the authorized manufacturer of lift?

- A:-Form D
- B:-Form A
- C:-Form F
- D:-Form G

Correct Answer:- Option-A

Question12:-Who is the authority to fix the time and place of KSEL Board meeting?

- A:-CEI
- B:-President
- C:-Secretary
- D:-Chairman KSEB

Correct Answer:- Option-B

Question13:-Who is to send notice to members of KSEL Board regarding meeting?

- A:-President
- B:-CEI
- C:-Secretary
- D:-Electrical Inspector

Correct Answer:- Option-C

Question14:-Who is the authority to prescribe syllabus for examinations of Supervisors and Wiremen?

- A:-KSERC
- B:-KSEB
- C:-KSELB
- D:-CEI

Correct Answer:- Option-C

Question15:-Kerala State Electricity Licensing Board is appointed by

- A:-Government
- B:-KSEB
- C:-CEI
- D:-KSERC

Correct Answer:- Option-A

Question16:-Which section of KC(R) Act, 1958 empower Government to suspend exhibition of film in certain cases?

- A:-4
- B:-9
- C:-11
- D:-12

Correct Answer:- Option-B

Question17:-Which rule in KC (R) Rules, 1988 insists fire resistant material for construction of corridors, floors, roof, balcony, etc. intended for public use in a cinema theatre?

- A:-108
- B:-112
- C:-106
- D:-100

Correct Answer:- Option-A

Question18:-What is the minimum width of seat in a theatre?

- A:-30 cm
- B:-50 cm
- C:-55 cm
- D:-45 cm

Correct Answer:- Option-D

Question19:-Which rule in KC(R) Rules, 1988 insists separate circuit for cinematography lamps?

- A:-48
- B:-64
- C:-46
- D:-35

Correct Answer:- Option-C

Question20:-What is the maximum height of fixing fire extinguisher from floor level in a cinema theatre auditorium?

- A:-1.00 m
- B:-1.50 m
- C:-1.20 m
- D:-1.75 m

Correct Answer:- Option-B

Question21:-The licensing authority to grant a license for cinematographic exhibition

- A:-Executive authority of Local body
- B:-State Government
- C:-Electrical Inspector
- D:-PWD

Correct Answer:- Option-A

Question22:-Which rule in KC(R) Rules, 1988 insists exhibition of the license obtained under KC(R) Rules, 1988 at conspicuous place?

- A:-22
- B:-16
- C:-11
- D:-18

Correct Answer:- Option-D

Question23:-Which rule in KC(R) Rules, 1988, prohibits addition/alteration to that premises of which permission has been granted or any other part thereof, without the sanction of the Licensing Authority being obtained without plans and drawings relating to such addition alteration?

- A:-11
- B:-12
- C:-10
- D:-80

Correct Answer:- Option-C

Question24:-Which rule in KC(R) Rules, 1988 insists suitable shelter against sun and rain for the would be purchaser of tickets in queues?

- A:-95
- B:-101
- C:-103
- D:-98

Correct Answer:- Option-B

Question25:-Term of office of the KSELB member other than the ex-officio member is

- A:-3 years
- B:-5 years
- C:-2 years
- D:-10 years

Correct Answer:- Option-A

Question26:-Which rule in KSELB Rules insists a registered office in Kerala for getting 'A' grade electrical contractor license?

- A:-50
- B:-49
- C:-42
- D:-40

Correct Answer:- Option-D

Question27:-Which rule in KSELB Rules insists production units to obtain contractor's license?

- A:-61
- B:-68
- C:-62
- D:-50

Correct Answer:- Option-C

Question28:-Under which section of the Kerala Electricity Duty Act, 1963 Government levies electricity duty in sale of energy by Licensees?

- A:-section 4
- B:-Section 3
- C:-Section 5 A
- D:-Section 4

Correct Answer:- Option-B

Question29:-Which section of KSE Duty Act, 1963 imposes penalty for violation of Sections of the Duty Act?

- A:-9
- B:-8
- C:-7
- D:-6

Correct Answer:- Option-A

Question30:-Which section of Kerala Electricity Duty Act, 1963 insists the licensee to keep books of accounts in prescribed form?

- A:-5
- B:-3
- C:-28
- D:-6

Correct Answer:- Option-D

Question31:-Which rule in KE(R) Rules, 1988 insists separate circuit for outdoor wiring in a cinema theatre?

- A:-108
- B:-90
- C:-110(2)
- D:-112

Correct Answer:- Option-C

Question32:-Which rule in KC (R) Rules, 1988 prohibits inflammable material inside enclosure of cinema theatre?

- A:-40
- B:-43
- C:-46
- D:-50

Correct Answer:- Option-B

Question33:-According to which rule of KC(R) Rules, 1988 operator shall satisfy himself before commencement of each performance all electrical installations are in tact.

- A:-50(3)
- B:-31(ii)
- C:-35(3)
- D:-13(4)

Correct Answer:- Option-A

Question34:-What is the minimum size of cable for light circuit inside the auditorium of the theatre?

- A:-6.0
- B:-1.5
- C:-4.0
- D:-2.5

Correct Answer:- Option-D

Question35:-Which rule in KC(R) Rules, 1988 insists emergency lighting system with batteries in the theatre?

- A:-116
- B:-112(1)
- C:-110
- D:-86

Correct Answer:- Option-B

Question36:-What is the minimum height of exit door of auditorium of a cinema theatre is?

- A:-2 m
- B:-1.5 m
- C:-2.1 m
- D:-3 m

Correct Answer:- Option-C

Question37:-Which rule in KC(R) Rules, 1988 prohibits providing loud speaker outside the auditorium of a theatre, except in panchayath area?

- A:-112(7)
- B:-110
- C:-96
- D:-88

Correct Answer:- Option-A

Question38:-Which rule in KC(R) Rules, 1988 prohibits subsequent addition/ alteration at theatre for which license has been granted, without sanction of licensing authority?

- A:-8
- B:-10
- C:-12
- D:-24

Correct Answer:- Option-D

Question39:-Which rule in KC(R) Rules, 1988 prohibits smoking in the auditorium?

- A:-100
- B:-105
- C:-110
- D:-90

Correct Answer:- Option-B

Question40:-Which rule in KC(R) Rules, 1988 insists exhibition of plan in single line of the wiring at office of the manager of the theatre?

- A:-109(2)
- B:-100
- C:-112
- D:-118

Correct Answer:- Option-A

Question41:-Which rule in KC(R) Rules, 1988 insists a double pole switch in cinematography lamp circuit?

- A:-40
- B:-45
- C:-47
- D:-36

Correct Answer:- Option-C

Question42:-Application for permission under Section 6 of KC(R) Act, 1958 shall be submitted in

- A:-Form E
- B:-Form D
- C:-Form C
- D:-Form A

Correct Answer:- Option-D

Question43:-Application for renewal of 'D' certificate shall be made minimum _____ month before the expiry of existing license.

- A:-Two
- B:-One
- C:-Three
- D:-Six

Correct Answer:- Option-B

Question44:-Which rule in KSELB Rules empower the Board to cancel the supervisor License / permit issued?

- A:-56
- B:-50
- C:-58
- D:-46

Correct Answer:- Option-A

Question45:-Which rule in KSELB Rules prohibits KSEB from doing electrical installation work at consumers premises?

- A:-50
- B:-59
- C:-60
- D:-40

Correct Answer:- Option-C

Question46:-Which rule in KSELB Rules insists notice of commencement of work?

- A:-63
- B:-38
- C:-46
- D:-50

Correct Answer:- Option-D

Question47:-Which rule in KSELB Rules relates authorising Board for prescribed forms and registers?

- A:-63
- B:-61
- C:-60
- D:-58

Correct Answer:- Option-A

Question48:-Which rule in KSELB Rules permit Electrical Inspector to enter, inspect and examine all premises of electrical installation?

- A:-48
- B:-58
- C:-50
- D:-52

Correct Answer:- Option-B

Question49:-Which rule in KSELB Rules insists Test report for all electrical installation work?

- A:-38
- B:-49
- C:-50
- D:-51

Correct Answer:- Option-D

Question50:-What is the minimum age for getting supervisor permit?

- A:-17 years
- B:-21 years
- C:-18 years
- D:-65 years

Correct Answer:- Option-C

Question51:-Which rule in the Kerala Electricity Duty Rules, 1963 insists installation of energy meter in stand by Generator sets?

- A:-3
- B:-9A
- C:-10
- D:-4

Correct Answer:- Option-B

Question52:-Which section of KED Act, 1963 imparts power to the Government to exempt from payment of electricity duty?

- A:-11
- B:-6
- C:-10
- D:-15

Correct Answer:- Option-A

Question53:-KED Rules, 1963 is formulated under _____ section of KED Act, 1963.

- A:-12
- B:-11
- C:-13
- D:-10

Correct Answer:- Option-C

Question54:-Consumer who generates and consume energy for their own purpose have to pay Electrical Duty under Section _____ of KED Act, 1963.

- A:-5
- B:-4
- C:-3
- D:-2

Correct Answer:- Option-B

Question55:-_____ Section of KED Act, 1963 imposes penalty for failure to keep books and accounts.

- A:-10
- B:-9
- C:-8

D:-11

Correct Answer:- Option-B

Question56:-Which rule KED Rules, 1963 necessitates the Licensee to record the energy meter reading of standby generator units?

A:-9

B:-8

C:-6

D:-11

Correct Answer:- Option-A

Question57:-Which rule in Kerala Electricity Duty Rules, 1963 envisages penalty for breach of Rules?

A:-2

B:-10

C:-11

D:-13

Correct Answer:- Option-C

Question58:-Which Section of the Kerala Cinemas (Regulation) Act, 1958 empowers the Government to make rules?

A:-13

B:-11

C:-2

D:-4

Correct Answer:- Option-A

Question59:-What is the minimum number of electric lighting circuits in a cinema theatre?

A:-4

B:-3

C:-2

D:-None of these

Correct Answer:- Option-B

Question60:-Which rule in KC(R) Rules, 1988 insists the licensee to properly maintain electrical installation and A/C plant?

A:-110

B:-113

C:-111

D:-112(10)

Correct Answer:- Option-D

Question61:-Which rule in KSELB Rules insist that the Secretary KSELB shall maintain a register of all licensed electrical contractors?

A:-12

B:-52

C:-50

D:-46

Correct Answer:- Option-B

Question62:-Which rule empowers Licensing Board to enquire in to allegation, or breach of rules against a licensed contractor?

A:-5(iv)

B:-11(iii)

C:-2(g)

D:-17(a)

Correct Answer:- Option-A

Question63:-Maximum Validity of 'D' certificate to a permanent theatre is

A:-1 year

B:-2 years

C:-3 years

D:-4 years

Correct Answer:- Option-C

Question64:-Maximum area of openings in front of the enclosure of a cinema theatre for projection and observation shall be

A:-0.5 sq.m

B:-5.0 sq.m

C:-0.2 sq.m

D:-0.3 sq.m

Correct Answer:- Option-D

Question65:-What is the minimum width of treads of staircase in a theatre shall be

A:-30 cm

B:-50 cm

C:-10 cm

D:-20 cm

Correct Answer:- Option-A

Question66:-Which rule in KC(R) Rules, 1988 insists A/C units running throughout the show time in an A/C Theatre?

A:-109(3)

B:-111(3)

C:-112(9)

D:-114(1)

Correct Answer:- Option-C

Question67:-In which form the certificate of suitability of electrical installation in cinema theatre is given?

A:-Form A

B:-Form D

C:-Form C

D:-Form E

Correct Answer:- Option-B

Question68:-Which rule in KC(R) Rules, 1988 insists wiring in conduit only in the auditorium and projection room?

A:-116

B:-109

C:-112

D:-110(4)

Correct Answer:- Option-D

Question69:-What is the minimum back to back distance of seats in the auditorium of a theatre?

A:-85 cm

B:-80 cm

C:-75 cm

D:-70 cm

Correct Answer:- Option-A

Question70:-What is the minimum width of passage or corridor landing from an exit door of cinema theatre auditorium?

A:-0.75 m

B:-2.0 m

C:-1.5 m

D:-3.0 m

Correct Answer:- Option-C

Question71:-What is the minimum capacity of soda acid type fire extinguisher provided at the auditorium?

A:-10 litre

B:-15 litre

C:-5 litre

D:-7.5 litre

Correct Answer:- Option-A

Question72:-What is the minimum number of portable fire extinguishers is to be provided in the auditorium?

A:-2

B:-4

C:-6

D:-8

Correct Answer:- Option-B

Question73:-How many portable fire extinguisher is required inside the enclosure?

A:-4

B:-5

C:-3

D:-1

Correct Answer:- Option-D

Question74:-Which rule in KC(R) Rules, 1988 insists separate circuit for outdoor wiring?

A:-107

B:-108

C:-110(2)

D:-109

Correct Answer:- Option-C

Question75:-Which rule in KC(R) Rules, 1988 insists providing separate energy meter for measuring the energy consumed by A/C system in A/C theatre?

A:-113

B:-115

C:-110

D:-112(9)

Correct Answer:- Option-D

Question76:-Minimum height of hand rails provided for ramp in a theatre shall be

A:-500 mm

B:-1000 mm

C:-800 mm

D:-130 mm

Correct Answer:- Option-C

Question77:-What is the minimum distance of the farthest point in a cinema building from where the staircase affords access?

A:-20 m

B:-10 m

C:-15 m

D:-30 m

Correct Answer:- Option-A

Question78:-Minimum width of clear aisles in auditorium of a theatre shall be

A:-1.0 m

B:-1.2 m

C:-1.5 m

D:-2.0 m

Correct Answer:- Option-B

Question79:-Minimum floor area required for 20 seats having back and arms in a permanent theatre is

A:-9.00 sq.m

B:-12 sq.m

C:-11.5 sq.m

D:-9.50 sq.m

Correct Answer:- Option-D

Question80:-Which rule in KC(R) R, 1988 insists the requirement of artificial ventilation in the auditorium?

A:-101(1)

B:-115(1)

C:-114(1)

D:-112(1)

Correct Answer:- Option-C

Question81:-For an auditorium of 600 sq.m area how many exhaust fans are required?

A:-12

B:-8

C:-6

D:-18

Correct Answer:- Option-A

Question82:-For an auditorium of 400 seating capacity how many ceiling fans are required?

A:-6

B:-8

C:-4

D:-2

Correct Answer:- Option-B

Question83:-What is the minimum capacity of Dry Chemical Powder type fire extinguisher used in a theatre?

A:-5 kg

B:-3 kg

C:-1 kg

D:-10 kg

Correct Answer:- Option-A

Question84:-Which Section of the Kerala Cinemas (Regulation) Act, 1958 empower licensing authority to issue direction to any licensee to show slides of public interest?

A:-Section 3

B:-Section 7

C:-Section 5

D:-Section 8

Correct Answer:- Option-D

Question85:-What is the maximum steepness of ramp in a theatre according to Rule 81(2) of KC(R) Rules, 1988?

A:-1:5

B:-3:4

C:-1:6

D:-2:4

Correct Answer:- Option-C

Question86:-By which rule in KC(R) Rules, 1988 the licensing authority shall not issue license in the absence of 'D' certificate?

A:-10

B:-15

C:-24

D:-35

Correct Answer:- Option-B

Question87:-What is the minimum width of exit door of the auditorium of a cinema theatre shall be?

A:-1.5 m

B:-2.5 m

C:-1.0 m

D:-3.0 m

Correct Answer:- Option-A

Question88:-What is the minimum age for a cinema operator?

A:-15 years

B:-16 years

C:-25 years

D:-18 years

Correct Answer:- Option-D

Question89:-Which rule in KC(R) Rules, 1988 prohibits entry of unauthorised person to enclosure?

A:-30

B:-42

C:-41

D:-40

Correct Answer:- Option-C

Question90:-Which rule in KC(R) Rules, 1988 restrict construction of a permanent cinema near a temporary cinema?

A:-25(1)(2)

B:-28(2)(a)

C:-29(2)(a)

D:-30(1)(b)

Correct Answer:- Option-B

Question91:-Who is the authority to issue licence to Cinema operator?

A:-CEI

B:-Government

C:-KSEL Board

D:-Electrical Inspector

Correct Answer:- Option-A

Question92:-What is the minimum height of bottom of the screen from the ground level of the front row of seat in the auditorium?

A:-2.0 m

B:-1.5 m

C:-2.5 m

D:-2.1 m

Correct Answer:- Option-D

Question93:-What is the minimum height of auditorium?

A:-10 m

B:-5 m

C:-6 m

D:-4.5 m

Correct Answer:- Option-C

Question94:-Which rule in KC(R) Rules, 1988 imparts power to enter a cinema to the Chief Electrical inspector or his nominee?

A:-34

B:-35(3)

C:-12

D:-9

Correct Answer:- Option-B

Question95:-Who is empowered to make rules under section 13 of KED Act, 1963?

A:-CEA

B:-KSELB

C:-Govt.

D:-KSEB

Correct Answer:- Option-C

Question96:-Which rule in KC(R) Rules, 1988 insists testing of fire extinguisher once in two years by Fire Force Department?

A:-107(iv)

B:-106

C:-113

D:-109

Correct Answer:- Option-A

Question97:-Who is the authority to issue competence certificate to cinema operator?

A:-CEI

B:-Board of Examiners
C:-Govt.
D:-KSELB

Correct Answer:- Option-B

Question98:-What is the rate of electricity duty for consumption in case of a domestic consumer?

A:-10 paise per unit
B:-Nil
C:-1.2 paise per unit
D:-10% of price of energy
Correct Answer:- Option-D

Question99:-What is the fee for permission to erect an escalator?

A:-Rs. 1,500
B:-Rs. 500
C:-Rs. 2,000
D:-Rs. 1,000
Correct Answer:- Option-C

Question100:-What is the form of completion report of electrical works of a lift installation?

A:-Form E
B:-Form D
C:-Form F
D:-Form G
Correct Answer:- Option-A