



KERALA PUBLIC SERVICE COMMISSION

EST1A3/5/2024-KPSC

Thiruvananthapuram
Dated :25.06.2024

കാട്ടേഷൻ നോട്ടീസ്

Quotation No: EST/7/2024

കേരള പബ്ലിക് സർവീസ് കമ്മീഷൻ ആസ്ഥാന ഓഫീസിൽ താഴെപ്പറയുന്ന സ്പെസിഫിക്കേഷൻ പ്രകാരമുള്ള 42U Network Rack/Server Rack വിതരണം ചെയ്തു സ്ഥാപിക്കുന്നതിനായി മത്സരാടിസ്ഥാനത്തിലുള്ള കാട്ടേഷനുകൾ ക്ഷണിക്കുന്നു.

Specification for 42U Network /Server Rack

1	Racks manufactured out of steel sheet punched, formed,welded and powder coated
2	Racks should be from ISO 14001,27000 Certified Company.
3	Rack should be UL Listed.
4	Standard for Racks configuration will be CKD frame and side panels and vented top cover.
5	Rack should have Front and Rear dual perforated door.
6	Rack should have 2 Nos of removable side panel with slam latch.
7	Rack should have provision to mount racks on floor.
8	Rack should be 42U(1U=44.45 mm)in height.
9	It should be 800mm wide, 1200mm deep and overall height 2115 mm
10	Rack should include adopter kit 1 no closed type.
11	Rack should conforms to DIN 41494 or equivalent EIA/ISO/EN standard.
12	Rack should have Adjustable mounting depth.
13	Rack 4 no.s adjustable,19” verticals with punched 9mm square hole and universal 12.7 mm-15.875mm-15.875mm alternating hole pattern offers greater mounting flexibility, maximizes usable mounting space.
14	Rack should have numbered U positions.
15	Rack should have 100% assured compatibility with all equipments conforming to DIN 41494(General industrial standard for equipments)
16	Powder coated finish with seven tanks pre-treatment process meeting IS
17	Rack should have proper grounding & bonding.
18	Rack should have fan module mount provision on top cover
19	Rack should have fan tray with 4 no's 90 CFM fan
20	Rack should have 2 No.s fixed shelf with 715 mm depth for mounting non rack mountable equipment .

21	Rack should have 2 Horizontal Cable Manager 2 U Channel on front.
22	Rack should have 2 No.s 300MM cable basket
23	Rack should have 2 No.s Server/IT Rack mount power distribution unit, 1Ph,230V,32A,50/60Hz, Zero U standard with 12 X Indian Round Pin 5/15A, 16A MCB X2 Circuits-PDU Rating 7.3 KVA/Bottom feed-3Mt/Black/Inlet plug not installed.
24	Rack should have 2 No.s Server/IT Rack mount power distribution unit, 1Ph,230V,16A,50/60Hz, 2 U standard with 6 X Indian Round Pin 5/15A, Inlet Plug type 16A Indian Round Pin ,16A MCB-PDU Rating 3.6 KVA/Side feed-3Mt/Black.
25	Rack should have provision for cable entry, exit from both top & bottom.
26	Rack should have 4 packet of mounting hardware, pack of 20.
27	The products manufactured should provide warranty for 3 years from date of invoice.
28	Electrical items such as sockets ,fans etc should have warranty for 1 year from date of installation.
29	For malfunction of any units/item in the rack, the support should be provided within the next business day.
30	The warranty claim should be attended within 2 or 3 working days.
31	Bidder need to submit Manufacturer Authorisation Letter.

കാട്ടേഷനുകൾ സീൽ ചെയ്ത കവറിൽ '42U Network/Server Rack വിതരണം ചെയ്യുന്നതിനുള്ള കാട്ടേഷൻ ' എന്ന മേൽക്കുറിപ്പോടെ " സെക്രട്ടറി, കേരള പബ്ലിക് സർവീസ് കമ്മീഷൻ ,പട്ടം പാലസ് പി .ഒ , തിരുവനന്തപുരം -4" എന്ന മേൽവിലാസത്തിൽ 10 /07/2024 തീയതി 1.00 pm മണിക്ക് മുൻപായി ലഭിച്ചിരിക്കേണ്ടതാണ്. കാട്ടേഷനുകൾ അന്നേ ദിവസം 3.00 pm മണിക്ക് ബന്ധപ്പെട്ട ഉദ്യോഗസ്ഥരുടെയും , അധികാരപ്പെടുത്തിയ ആളുകൾ ഹാജരായാൽ അവരുടെയും സാന്നിധ്യത്തിൽ തുറക്കുന്നതും , തുടർ നടപടികൾ സ്വീകരിക്കുന്നതുമാണ്.

കാട്ടേഷൻ അംഗീകരിക്കപ്പെടുകഴിഞ്ഞാൽ നിശ്ചയിക്കപ്പെടുന്ന തീയതിക്ക് പ്രസ്തുത ബുക്ക് സ്കാനർ ഓഫീസിൽ എത്തിക്കേണ്ടതാണ്. സ്കാനർ സ്ഥാപിച്ച ശേഷം, തുക ട്രഷറി മുഖാന്തിരം അക്കൗണ്ടിലേക്കു മാറി നൽകുന്നതായിരിക്കും .

കാട്ടേഷനുകൾ സ്വീകരിക്കുന്നതിനും , കാരണം കാണിക്കാതെ നിരസിക്കുന്നതിനുമുള്ള അധികാരം കേരള പബ്ലിക് സർവീസ് കമ്മീഷൻ സെക്രട്ടറിയിൽ നിക്ഷിപ്തമാണ്. വിശദ വിവരങ്ങൾക്ക് സെക്രട്ടറി, കേരള പബ്ലിക് സർവീസ് കമ്മീഷൻ , പട്ടം പാലസ് പി.ഒ, തിരുവനന്തപുരം എന്ന മേൽവിലാസത്തിൽ പ്രവർത്തി സമയത്ത് ബന്ധപ്പെടാവുന്നതാണ് . ഫോൺ നമ്പർ :0471 2546250

Sd/-
സാജു ജോർജ്ജ്
സെക്രട്ടറി
കേരള പബ്ലിക് സർവീസ് കമ്മീഷൻ

**To
Website
PR Unit**