

FINAL ANSWER KEY

Paper: Kerala State Electricity Duty Act and Rules ...(Paper II)
Date of Examination: 05-09-2019

Question1:-The clearance between back of one seat and front of the seat immediately behind measured between perpendiculars is _____

- A:-50 cm
- B:-35 cm
- C:-30 cm
- D:-60 cm

Correct Answer:- Option-B

Question2:-Minimum distance between screen and front edge of first row of seating is _____

- A:-4 m
- B:-3.5 m
- C:-4.5 m
- D:-5 m

Correct Answer:- Option-A

Question3:-In a cinema hall with balcony, the height between the floor of the highest part of the seating and the lowest part of the ceiling over the same shall be minimum _____

- A:-2.4 m
- B:-3 m
- C:-3.7 m
- D:-2.9 m

Correct Answer:- Option-C

Question4:-All questions arises as to the interpretation of the KC(R) Rules 1988, otherwise than in connection with the procecution for an offence shall be referred to the _____

- A:-District Collector
- B:-Licensing Authority
- C:-State Government
- D:-Chief Electrical Inspector

Correct Answer:- Option-C

Question5:-The back to back distance of chairs shall be minimum _____ as specified in Rule 94 of KC(R)R.

- A:-70 cm
- B:-100 cm
- C:-95 cm
- D:-85 cm

Correct Answer:- Option-D

Question6:-For non-A/C theatres the requirement of exhaust fans is one for every _____ square meter of the auditorium.

- A:-40
- B:-50
- C:-60
- D:-55

Correct Answer:- Option-B

Question7:-The height of hand-rail of ramps in cinema buildings shall not be less than _____

- A:-50 cm
- B:-70 cm
- C:-90 cm
- D:-80 cm

Correct Answer:- Option-D

Question8:-Minimum width required for cross aisles inside the cinema auditorium shall be _____

- A:-1 m
- B:-0.5 m

C:-0.75 m

D:-0.8 m

Correct Answer:- Option-A

Question9:-The slope of the ramps in cinema Building shall be _____

A:-1:5

B:-1:2

C:-1:6

D:-1:4

Correct Answer:- Option-C

Question10:-The size of the opening in front of the enclosure shall not be larger than _____ square meter.

A:-0.4

B:-0.3

C:-0.5

D:-0.2

Correct Answer:- Option-B

Question11:-The minimum number of fire extinguishers to be provided in the enclosure of cinema theatre is _____

A:-One

B:-Two

C:-Four

D:-Three

Correct Answer:- Option-A

Question12:-The maximum height at which the screen shall be fixed above ground level of the front row of seats is _____

A:-2 m

B:-1.8 m

C:-2.4 m

D:-2.1 m

Correct Answer:- Option-D

Question13:-To erect a lift the application in form A is to be submitted by the owner to the _____

A:-Local Authority

B:-Assistant Engineer PWD

C:-Assistant Engineer KSEBL

D:-Electrical Inspector

Correct Answer:- Option-D

Question14:-_____ for erecting lift is issued in Form B.

A:-Permit

B:-License

C:-Completion report

D:-None of the above

Correct Answer:- Option-A

Question15:-For obtaining lift license Form D shall be submitted by the _____

A:-Electrical contractor

B:-Manufacturer

C:-Supervisor

D:-Owner

Correct Answer:- Option-B

Question16:-Lift and Escalator licenses are granted as per section _____ of Kerala lift and Escalator Act 2013.

A:-3

B:-5

C:-4

D:-2

Correct Answer:- Option-C

Question17:- _____ has the power to cancel or suspend lift license.

A:-Municipal secretary

B:-Village Officer

C:-Electrical Inspector

D:-Assistant Engineer KSEB

Correct Answer:- Option-C

Question18:-Penalty charged for contravenes any of the provisions of Kerala lifts and escalator Act 2013 is _____

A:-2000

B:-1000

C:-1500

D:-5000

Correct Answer:- Option-D

Question19:-Rule _____ of Kerala Lifts and escalator Rules 2012 allows to make an appeal to the Chief Electrical Inspector.

A:-6

B:-7

C:-5

D:-8

Correct Answer:- Option-D

Question20:-Any accident that occurs in an escalator installation shall be reported as per rule _____

A:-5

B:-3

C:-10

D:-8

Correct Answer:- Option-C

Question21:-Validity of permit issued for erecting escalators is for _____

A:-6 months

B:-One year

C:-2 years

D:-3 years

Correct Answer:- Option-B

Question22:-Minimum number of qualified electricians required for an authorized manufacturer of lifts and escalator is _____

A:-8

B:-5

C:-4

D:-6

Correct Answer:- Option-B

Question23:-President of the Kerala State Electricity Licensing Board is

A:-Power Secretary

B:-Chief Electrical Inspector

C:-Additional Chief Electrical Inspector

D:-Chief Engineer, KSEBL

Correct Answer:- Option-A

Question24:-The term of office of members other than the ex-officio members of the KSELB shall be _____

A:-3 years

B:-4 years

C:-2 years

D:-2 1/2 years

Correct Answer:- Option-A

Question25:-The _____ shall exercise proper check over accounts of KSELB.

- A:-Secretary
 - B:-President
 - C:-Ex-officio member
 - D:-Electrical Inspector
- Correct Answer:- Option-A

Question26:-Which one among the following is a member of KSELB?

- A:-Electrical Supervisor having Permit 'A'
 - B:-M.L.A.
 - C:-Electrical Supervisor having Permit 'B'
 - D:-M.P.
- Correct Answer:- Option-B

Question27:-If a member of KSELB other than an ex-officio one leaves state for more than _____ another person may be appointed in that place for the unexpired portion of the term of office.

- A:-3 months
 - B:-6 months
 - C:-One year
 - D:-4 months
- Correct Answer:- Option-B

Question28:-Which Rule of KSELB Rules enables the board to cancel, withdraw or suspend the permits granted?

- A:-15
 - B:-30
 - C:-33
 - D:-25
- Correct Answer:- Option-C

Question29:-The power of exemption to grant "A Class" contractor license to a person or firm not having registered office in Kerala is with the _____

- A:-Kerala Government
 - B:-KSELB
 - C:-KSEB
 - D:-Chief Electrical Inspector
- Correct Answer:- Option-B

Question30:-Report of commencement of works shall be submitted to the Electrical Inspector as per Rule _____ of KSELB Rules.

- A:-45
 - B:-38
 - C:-40
 - D:-50
- Correct Answer:- Option-D

Question31:-The form of test report as per Rule 51 of KSELB Rules is prescribed by the

- A:-Licensing Board
 - B:-Contractor
 - C:-Supply Authority
 - D:-Supervisor
- Correct Answer:- Option-A

Question32:-The power to dispense with or relax the requirement of any rule, of KSELB Rules, which causes undue hardship in any particular case lies with the _____

- A:-Licensing Board
 - B:-KSERC
 - C:-State Government
 - D:-None of the above
- Correct Answer:- Option-C

Question33:-As per section 2 of The Kerala Electricity supply code 2014 the average power factor is rounded off to _____ decimal places.

- A:-One
- B:-Three
- C:-Two
- D:-Four

Correct Answer:- Option-C

Question34:-An Industrial unit which consumes electricity at HT or EHT level for induction arc furnace is called

- A:-Melting Unit
- B:-Process Industry
- C:-Steel Forging Industry
- D:-Power Intensive Unit

Correct Answer:- Option-D

Question35:-An efficient, co-ordinated, economical distribution system shall be developed and maintained by the _____

- A:-State Government
- B:-Transmission Licensee
- C:-Consumers
- D:-Distribution Licensee

Correct Answer:- Option-D

Question36:-For supplying a voltage other than normal voltage levels specified for LT, HT and EHT systems approval of _____ is required.

- A:-State Government
- B:-KSEBL
- C:-Electrical Inspectorate
- D:-KSERC

Correct Answer:- Option-D

Question37:-The Kerala Electricity Supply Code 2014 came into force with effect from

- A:-01.01.2014
- B:-31.01.2014
- C:-01.03.2014
- D:-01.04.2014

Correct Answer:- Option-D

Question38:-The maximum contract demand permissible for low tension consumers who avails power under demand based metering shall be _____

- A:-100 KVA
- B:-100 KW
- C:-150 KVA
- D:-150 KW

Correct Answer:- Option-A

Question39:-Which section of the Kerala Electricity Supply Code 2014 grant permission for dedicated feeder at the request of the consumer?

- A:-12
- B:-13
- C:-15
- D:-10

Correct Answer:- Option-B

Question40:-Which section of the KES Code 2014 insists the wiring works at the consumer premises shall be carried out by a licensed electrical contractor?

- A:-15
- B:-20
- C:-11
- D:-14

Correct Answer:- Option-A

Question41:-What is the maximum permissible difference in loading between phase?

- A:-3%

B:-5%

C:-10%

D:-None of the above

Correct Answer:- Option-B

Question42:-What is parallel operation charge?

A:-Charge paid by a second party to a first party who operates a generator and share its power with the former

B:-Charge paid by an LT consumer, in a multistoried building, to the building owner

C:-Charge paid by a consumer to the licensee for operating his generator synchronized to the grid

D:-Charge paid by a consumer to the KSEBL for using stand by generator

Correct Answer:- Option-C

Question43:-Penal charges for failure to comply with effective harmonic control is determined by the _____

A:-Licensee

B:-State Government

C:-KSERC

D:-Chief Electrical Inspector

Correct Answer:- Option-C

Question44:-Which section of KES Code 2014 insists for energisation approval from Electrical Inspector mandatory before energising HT/EHT installations?

A:-52

B:-53

C:-56

D:-55

Correct Answer:- Option-B

Question45:-Which one listed below is not true about consumers with protected load status?

A:-Protected load status is granted in exceptional cases to essential services

B:-Consumers with protected load status are given supply through a dedicated feeder at 11 KV or above

C:-Protected load consumers may subjected to any emergency load shedding as ordered by the State Load Despatch Centre

D:-No restriction on consumption of power during scheduled power cut periods

Correct Answer:- Option-D

Question46:-A builder who proposes to avail single point supply to his multistoried building shall submit to the _____ an application with detailed project reports on the scheme for giving supply to all beneficiaries.

A:-Licensee

B:-KSERC

C:-Electrical Inspector

D:-Local Authority

Correct Answer:- Option-A

Question47:-The tariff applicable to the single point supply shall be determined by the _____

A:-Licensee

B:-Government

C:-KSERC

D:-None of the above

Correct Answer:- Option-C

Question48:-The application for reduction of connected load or contract demand of an HT consumer shall be accepted by the licensee only after _____ from the date of the original energisation of the connection.

A:-One year

B:-6 months

C:-2 years

D:-4 months

Correct Answer:- Option-A

Question49:-Parallel operation of the generator of a consumer with the supply system of licensee shall be carried out in co-ordination with

A:-State transmission utility

B:-State Load Despatch Centre

C:-Distribution licensee

D:-All of the above

Correct Answer:- Option-D

Question50:-What is the minimum time period given by the licensee to the consumer for effective implementation of harmonics control?

A:-6 months

B:-4 months

C:-8 months

D:-12 months

Correct Answer:- Option-A

Question51:-Which section of Kerala Electricity Duty Act 1963 insists installation of energy meter to measure the energy generated by a person/firm?

A:-Section 3

B:-Section 4

C:-Section 5A

D:-Section 8

Correct Answer:- Option-C

Question52:-Rate of electricity duty for industrial consumer at 11 KV and above is _____

A:-10% of electricity charges

B:-10 paise/unit of electricity consumed

C:-5% of electricity charges

D:-Nil

Correct Answer:- Option-B

Question53:-Time period of electricity duty payment by the licensee is _____

A:-One month

B:-Three months

C:-Four months

D:-Six months

Correct Answer:- Option-A

Question54:-Rate of duty collection charges for the energy consumed by the licensee is

A:-2% of the duty collected

B:-1% of the duty collected

C:-Nil

D:-None of the above

Correct Answer:- Option-C

Question55:-Yearly return of electricity duty is submitted in _____

A:-Form C

B:-Form E

C:-Form B

D:-None of the above

Correct Answer:- Option-A

Question56:-Penalty for breach of Kerala Electricity Duty Rules 1963 is imposed under Rule _____

A:-11

B:-10

C:-12

D:-9

Correct Answer:- Option-A

Question57:-Monthly returns of electricity duty are submitted in forms A and B to the _____

A:-Licensee

B:-Government

C:-Inspecting Officer

D:-None of the above

Correct Answer:- Option-C

Question58:-Rate of interest charged on arrears of electricity duty?

A:-10%

B:-8%

C:-15%

D:-18%

Correct Answer:- Option-D

Question59:-Electricity duty from consumers is collected by the licensee and paid to the _____

A:-Inspecting Officer

B:-Government

C:-Supply Authority

D:-District Administration

Correct Answer:- Option-B

Question60:-Rate of electricity duty for street lighting in Panchayath area is _____

A:-10% of electricity charges

B:-10 paise/unit of electricity consumed

C:-Nil

D:-None of the above

Correct Answer:- Option-C

Question61:-Electricity duty at the rate of _____ of the electricity charges is levied for industrial consumers below 11 KV.

A:-5%

B:-8%

C:-10%

D:-15%

Correct Answer:- Option-C

Question62:-Inspecting Officer is appointed under section _____ of the Kerala Electricity Duty Act 1963.

A:-5

B:-6

C:-8

D:-7

Correct Answer:- Option-D

Question63:-License to cinematograph exhibition is issued under section _____ of the Kerala Cinemas (Regulation) Act 1958.

A:-5

B:-3

C:-4

D:-10

Correct Answer:- Option-B

Question64:-While granting/refusing license, the interest of the public is considered as per section _____ of the KC(R) Act 1958.

A:-3

B:-5

C:-10

D:-8

Correct Answer:- Option-B

Question65:-The maximum number of slides that can be exhibited for public interest in any one show shall not be more than _____

A:-3

B:-2

C:-4

D:-5

Correct Answer:- Option-A

Question66:-The power to suspend the exhibition of films for any sufficient reason in respect of the whole of the state is associated with _____

- A:-The State Government
- B:-The District Collector
- C:-The Licensing Authority
- D:-None of the above

Correct Answer:- Option-A

Question67:-The maximum time to which slides of public interest shall be exhibited in any one show as per the directions of the licensing authority?

- A:-3 minutes
- B:-4 minutes
- C:-5 minutes
- D:-2 minutes

Correct Answer:- Option-B

Question68:-The application for constructing Cinema Building shall be submitted to the licensing authority in Form _____

- A:-D
- B:-C
- C:-A
- D:-E

Correct Answer:- Option-C

Question69:-Site plan of a proposed cinema theatre should clearly indicate the surrounding roads/buildings up to a distance of _____

- A:-200 m
- B:-100 m
- C:-150 m
- D:-400 m

Correct Answer:- Option-B

Question70:-For a cinema theatre building the structural soundness certificate is issued in _____

- A:-Form D
- B:-Form E
- C:-Form A
- D:-Form C

Correct Answer:- Option-D

Question71:-The validity of "D" certificate issued for cinema exhibition is _____ for temporary theatres.

- A:-One year
- B:-Three years
- C:-Six months
- D:-Two years

Correct Answer:- Option-A

Question72:-The validity of "C" certificate issued for permanent theatres is _____

- A:-One year
- B:-Two Years
- C:-Three years
- D:-Five years

Correct Answer:- Option-C

Question73:-Cinema operator license shall not be issued to a person having age more than _____ years.

- A:-50
- B:-65
- C:-62
- D:-60

Correct Answer:- Option-D

Question74:-Distance between two temporary cinemas within the jurisdiction of the same licensing authority shall not be less than _____

- A:-500 m

B:-700 m

C:-800 m

D:-None of the above

Correct Answer:- Option-C

Question75:-The Licensing Authority issues licence in Form _____ for cinema theatres.

A:-G

B:-C

C:-D

D:-E

Correct Answer:- Option-D

Question76:- _____ is the secretary of Kerala State Electricity Licensing Board.

A:-Power Secretary

B:-Chief Electrical Inspector

C:-Managing Director, KSEBL

D:-Deputy Chief Electrical Inspector

Correct Answer:- Option-D

Question77:-No candidate will normally be eligible for supervisors permit Grade 'A' or 'B' if he has completed the age of _____ years

A:-60

B:-66

C:-62

D:-65

Correct Answer:- Option-D

Question78:-A register of certificates and permits granted and KSELB Rules shall be maintained by the _____

A:-Secretary

B:-President

C:-Power Department

D:-Electrical Inspector

Correct Answer:- Option-A

Question79:-Notice of termination of service of supervisor/wiremen of a licensed Electrical Contractor shall be intimated to the _____

A:-Secretary

B:-Government

C:-KSEBL

D:-Electrical Inspector

Correct Answer:- Option-A

Question80:-

Which rule of KSELB Rules enables Electric Supply Authority to obtain Electrical Contractors License

A:-Rule 60

B:-Rule 61

C:-Rule 50

D:-Rule 45

Correct Answer:- Option-A

Question81:-A violation of KSELB Rules has reported to the Licensing Board from Thrissur District. Who will be investigation officer to forward the final report to the licensing board?

A:-Deputy Chief Electrical Inspector, Ernakulam

B:-Electrical Inspector, Thrissur

C:-Electrical Inspector, Palakkad

D:-Electrical Inspector, Malappuram

Correct Answer:- Option-B

Question82:-What action will be taken by the Licensing Board, when it is found that the electrical supply company to which contractors license granted, give preferential treatment to consumers with a view to gaining unfair advantage in competition with local contractors?

A:-Suspend the license for 6 months

- B:-Suspend the license for 12 months
 - C:-Suspend the license till enquiry report is finalised
 - D:-With draw the license granted
- Correct Answer:- Option-D

Question83:-Application for renewal of escalator license is submitted in Form _____

- A:-G
- B:-F
- C:-H
- D:-A

Correct Answer:- Option-A

Question84:-Along with the renewal application for the lift license, copy of _____ also shall be produced.

- A:-Previous License
- B:-Manufactures License
- C:-Third party insurance policy
- D:-None of the above

Correct Answer:- Option-C

Question85:-Who is responsible for the safe custody of meter and other equipments of the licensee at point of commencement of supply?

- A:-Licensee
- B:-Contractor
- C:-Consumer
- D:-Supervisor

Correct Answer:- Option-C

Question86:-Which section of KES Code 2014 insists for certification from Electrical Inspector before connecting the HT/EHT installations to the system of the licensee?

- A:-Section 25
- B:-Section 30
- C:-Section 26
- D:-Section 23

Correct Answer:- Option-C

Question87:-The application for reduction of connected load or contract demand of an LT can shall be accepted by the licensee only after _____ from the date of original energization of LT connection.

- A:-4 months
- B:-6 months
- C:-12 months
- D:-3 months

Correct Answer:- Option-B

Question88:-The electricity charges for street lighting in a Municipal area is paid by the _____

- A:-District Administration
- B:-Municipality
- C:-People residing in that area
- D:-Licensee

Correct Answer:- Option-B

Question89:-The energy meter installed in a domestic premises damaged due to server voltage fluctuations in the distribution system. The cost of replacement of the defective meter shall be borne by the _____

- A:-Consumer
- B:-Licensee
- C:-Shared by both Consumer and Licensee
- D:-None of the above

Correct Answer:- Option-B

Question90:-Under Rule _____ of KSELB Rules supervisor grad 'A' permit is issued.

- A:-25

B:-30

C:-28

D:-24

Correct Answer:- Option-C

Question91:-In a Panchayath, the permit for cinema theatre construction is issued in From _____

A:-E

B:-D

C:-A

D:-B

Correct Answer:- Option-D

Question92:-All exits from the cinema hall shall be clearly indicated by the word _____ in block letters.

A:-OUT

B:-DOOR

C:-EXIT

D:-Any of the above

Correct Answer:- Option-C

Question93:-Minimum width of the corridor from auditorium exit to the final space of exit of the cinema theatre shall be _____

A:-1.25 m

B:-1.4 m

C:-1.75 m

D:-1.5 m

Correct Answer:- Option-D

Question94:-The minimum number of steps in each flight shall be _____ as per KC(R) Rules 1988.

A:-4

B:-5

C:-6

D:-3

Correct Answer:- Option-D

Question95:-The electric lighting of the cinema premises shall have at least _____ distinct and separate main circuits.

A:-3

B:-2

C:-4

D:-5

Correct Answer:- Option-A

Question96:-The minimum front clearance of a cinema building shall be _____

A:-6 m

B:-5 m

C:-8 m

D:-7.5 m

Correct Answer:- Option-D

Question97:-The electrical installations both in the auditorium and the projection room in the same theatre shall be done only in _____

A:-Consealed wiring

B:-Conduits

C:-Reaper

D:-None of the above

Correct Answer:- Option-B

Question98:-The minimum width of seats as per KC(R)R 1988 should be _____

A:-50 cm

B:-45 cm

C:-55 cm

D:-60 cm

Correct Answer:- Option-B

Question99:-All gangways and steps shall be kept well illuminated as per Rule _____ of KC(R) Rules 1988.

A:-85

B:-87

C:-89

D:-90

Correct Answer:- Option-A

Question100:-What is the minimum rear side width to be provided for a cinema building as per Rule 59 of KC(R)R 1988?

A:-2 m

B:-1.5 m

C:-1.75 m

D:-2.3 m

Correct Answer:- Option-B